Addendum

Addendum No.: 2

Issue Date: September 24, 2018

Project: Martin Luther Evangelical Lutheran Church

Miscellaneous Improvements

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated August 27, 2018. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

A - BIDDER QUESTIONS AND ANSWERS

- 1. Bidders may, at their option, submit a bid for remediation of asbestos flooring/adhesive as detailed in the hazardous materials report in Appendix 2 of the bidding package.
- 2. Where walls to be demolished are on flooring containing hazardous materials, remediation shall be performed after the removal of the walls. Where walls to remain are on flooring containing hazardous materials, all materials will remain in place, with the hazardous materials being encapsulated by the existing construction.

B – CHANGES TO THE DRAWINGS

1. None

C – NEW DRAWINGS RELEASED

1. None